LAPD Phase 2

S. Pordes, B. Rebel, T. Yang, M. Stancari, S. Lockwitz, H. Jostlein

PAB May 2011



(Short) Bo TPC



- 50 L
- 3 wire planes, 60 degree rotation
- 4.7 mm wire spacing, 50 wires per plane
- Separation between wire planes 7 mm
- 0-3 kV cathode
- No light detector
- Purity monitor installed

Bo Cryostat & TPC

- Used in 2009 to develop ArgoNeut electronics and DAQ at the Proton Assembly Building (PAB) at Fermilab
- In 2011, warm amplifiers replaced with cold amplifiers (MSU)

Bo TPC with MSU cold electronics



- First cold CMOS electronics in a LArTPC
- Next step is cold ASIC

Cold electronics: 2011 cosmic runs

- Trigger on single pair of scintillator paddles outside cryostat
- Crude reconstruction of single straight tracks in stand-alone (not LArSoft) code to evaluate S/N
- LArSoft has geometry, event display works nicely, hit reconstruction currently crashes (event display crashes at the moment as well)

Warm amps S/N = 15







Drift Time



Amps in liquid S/N >30



Drift Time





A plane



B plane



C plane





A plane



B plane



C plane



“Long Bo” 2m long, ≤150 kV





Cosmic Ray Trigger

- “Pairs” of counters on opposite sides of the tank. (Hi-Lo to get muons traversing TPC)
- 2 pairs on each of 3 axes
- Muon direction perpendicular to wires
- Total rate ~1-2 Hz



Extra Counters



(from above)

- NOT to scale, or even close!
- Possible to rotate blue counters 30 deg. and have 6 axes for triggering

Flanges



Reality

- Limited vertical clearance from tank to roof
- Very difficult to add anything to the tank without removing TPC


30”

LAPD Phase 2 program

- 150 kV feedthrough voltage already achieved (nominal operation at 100 kV for 500 V/cm)
- Measure purity with CR muon tracks
- Fully characterize filter sizing and material performance
- Study the effect of varying the recirculation rate on the drift lifetime
- Perform studies of how quickly lifetimes can be recovered from (intentional) poisoning of the Argon

Open questions

- Can we measure purity better with the TPC than the purity monitors?
- Can we see dispersion effects ?
- Can we see the effect of positive ion build up?

Potential for LBNE R&D with LAPD

- Existing setup with CR trigger and straight muon reconstruction software already in place
- BUT very difficult to add anything inside cryostat without removing TPC.
- Can be used while the 35 ton is being modified
- Much easier to access TPC for small modifications

➢ light detector development

➢ electronics tests

➢ calibration system development

Just to show off







HV Feedthrough
H. Jostlein and S. Lockwitz





Tested to 150 kV